

Corrosion Protection of Class C5 High

Product Identification: General - Specific Applications

Serie(s)

TEOS, DM, ARES, KMT, KMP, PC, HC, NEO Modular - Monoblock, KT, NEO HC Outdoor Modular - Monoblock, NEO 66

Note(s) : 1) Customized products are also included in this statement

Manufacturer : TEKPAN A.S.

Address : Halilbeyli OSB. Parsa Cad. No.2 Kemalpaşa İZMİR / TURKEY

Corrosivity Category	Durability	Tests to be performed	Time of this test	System to be tested
C5	High	Natural salt spray test according to ISO 3227	1440 hours	Mild steel with harsh environment powder coating
		Water condensation test according to ISO 6270-4	720 hours	

The results of the product(s) described above with the provisions of the applied Standard(s) is demonstrated by full compliance with following regulations/guidelines:

Reference Number

ISO 12944-5
ISO 12944-6
ISO 16276-2
ISO 6270
ISO 3227
ISO 4628
ISO 4624
ISO 2409

Description

Protective paint systems
Laboratory performance test methods
Cross-cut testing and X-cut testing
Determination of resistance to humidity-condensation
Corrosion tests in artificial atmospheres-Salt spray tests
Evaluation of degradation of coatings-Degree of blistering
Pull-off test for adhesion
Cross-cut test

Signed for and on behalf of:

İZMİR / 18.04.2023
Place Date of issue

Aykut YANIK QSD
Name, function



Signature

This declaration is an attestation of conformity with the indicated Directive(s) but does not imply any guarantee of quality or durability. The instructions of the accompanying product documentation shall be observed.