

ATTESTATION OF CONFORMITY

Issued to: Tekpan Teknik Elektrik Kumanda Pano San. ve Turizm Tic. As.
Halilbeyli O.S.B. mahallesi Parsa caddesi No: 2 Kemalpasa
Izmir
Turkey

For the product: Empty enclosure for low-voltage switchgear and controlgear assemblies

Trade name: Tekpan

Type/Model: DM Small Series, DM Medium Series, DM Large Series

Ratings: IP66 (single door), IP54 (double door)

Manufactured by: Tekpan Teknik Elektrik Kumanda Pano San. ve Turizm Tic. As.
Halilbeyli O.S.B. mahallesi Parsa caddesi No: 2 Kemalpasa
Izmir
Turkey

Subject: Degree of protection (IP)

Requirements: IEC 60529:1989, A1:1999, A2:2013

Remarks: -


This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2256241.02-INC, dated 2 March 2023.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 3 April 2023

Number: 2275294.02-AOC

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed