

 **DEKRA**
Test Report

2155856.01-INC

Applicant : Tekpan Teknik Elk. Kumanda Pano San.
Ve Turizm Ticaret Ltd. Sti.
Istiklal Mh. 17.Sk. No:8
Ulucak-Kemalpasa
Izmir
Turkey

Application date : 30 October 2013

Order number : 215585600-INC

Product : Empty enclosure

Trademark : Tekpan

Type(s) : Teos Series (plus+ / standard)


Arnhem, 30 October 2013

Manufacturer/ Production site: Tekpan Teknik Elk. Kumanda Pano San.
Ve Turizm Ticaret Ltd. Sti.
Istiklal Mh. 17.Sk. No:8
Ulucak-Kemalpasa
Izmir, Turkey

Subject : Degree of protection provided by enclosure, IP65

Test requirements : IEC 60529:1989 + A1:1999
EN 60529:1991 + A1:2000

Conclusion : The tested sample complies with the specified requirements

Tested by : A.A.P.M. van Vught 

Checked by : C.C. Burger 

Bur

0395-13

© DEKRA Certification B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if DEKRA Certification B.V. has explicitly granted the right to carry a quality mark.

DEKRA Certification B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.