

No	: C.17-0900-R01
Participant	: Tekpan Teknik Elk. Kumanda Pano San. Ve Turizm Tic. A.Ş.
Manufacturer	: Tekpan Teknik Elk. Kumanda Pano San. Ve Turizm Tic. A.Ş.
Product Description	: Teos Series Form 4B Panel
Model	: Teos Series Form 4B Panel
Technical Data	: 2215 x 2110 x 610 mm 60 kA/300 ms - IP55 – 400 V
Test Standard	: IEC 61641:2014
Subject	: Testing – Arc Fault Tests
Applied Tests	: Arc Fault Test
Test Report Number	: 17-0900-R01
Certificate Date	: 03.08.2017

Person in Charge of Test

Ata Gürül ARSLANLI

Head of Testing Laboratory

Cahit GÖKSEL



FRL.64

[www.lvt.com.tr](http://www.lvt.com.tr)

