

# TEST CERTIFICATE

Issued to: **TEKPAN TEKNİK ELEKTRİK KUMANDA PANO SAN. VE TURİZM TİC. AŞ.**  
Kemalpaşa O.S.B. İstiklal Mh. 17 Sok. NO:8 Ulucak Kemalpaşa  
İzmir  
Turkey

For the product: **Low-voltage switchgear and controlgear assembly**

Trade name: **Tekpan**

Type/Model: **Teos Series (plus+/standard) 3200A**

Ratings: **I<sub>NA</sub> 3200 A, U<sub>e</sub> 400 V, U<sub>i</sub> 690 V, U<sub>imp</sub> 8 kV, IP41, IK10  
I<sub>cw</sub> 80 kA / 70 kA - 1 s / 50 kA - 3 s  
I<sub>cc</sub> 100 kA / 65 kA / 50 kA at 400 V  
For more details see annex**

Manufactured by: **TEKPAN TEKNİK ELEKTRİK KUMANDA PANO SAN. VE TURİZM TİC. AŞ.**  
Kemalpaşa O.S.B. İstiklal Mh. 17 Sok. NO:8 Ulucak Kemalpaşa  
İzmir  
Turkey

Subject: **Design verification**

Requirements: **IEC 61439-2:2011  
Clauses 10.2.2, 10.2.3, 10.2.5, 10.2.6, 10.2.7, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8,  
10.9, 10.10.2.3.5, 10.11, 10.12, 10.13, 8.101.**

Remarks: **-**


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2175131.01-INC, dated 27 June 2016.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 27 June 2016

Number: 2175131.100

DEKRA Certification B.V.



F.S. Strikwerda  
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396