

TEST CERTIFICATE

Issued to: TEKPAN TEKNİK ELEKTRİK KUMANDA PANO SAN. VE TURİZM TİC. AŞ.
Kemalpaşa O.S.B. İstiklal Mh. 17 Sok. NO:8 Ulucak Kemalpaşa
İzmir
Turkey

For the product: Low-voltage switchgear and controlgear assembly

Trade name: Tekpan

Type/Model: Teos Series (plus⁺/standard) 6300A

Ratings: I_{nA} 5200 A, U_e 415 V, U_i 690 V, U_{imp} 8 kV, IP40, IK10
 I_{cw} 15 kA / 70 kA / 100 kA / 110 kA - 1 s
 I_{cc} 70 kA / 100 kA at 415 V
For more details see annex

Manufactured by: TEKPAN TEKNİK ELEKTRİK KUMANDA PANO SAN. VE TURİZM TİC. AŞ.
Kemalpaşa O.S.B. İstiklal Mh. 17 Sok. NO:8 Ulucak Kemalpaşa
İzmir
Turkey

Subject: Design verification

Requirements: IEC 61439-2:2011
Clauses 10.2.2, 10.2.3, 10.2.5, 10.2.6, 10.2.7, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8,
10.9, 10.10.2.3.5, 10.11, 10.12, 10.13 and Annex AA

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2169868.01-INC, dated 11 February 2015.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 11 February 2015

Number: 2169868.100

DEKRA Certification B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396