



File E352599

Vol 1

Auth. Page 1

Issued: 2012-09-20

Revised: 2012-09-20

FOLLOW-UP SERVICE PROCEDURE  
(TYPE L)

INDUSTRIAL CONTROL PANELS  
(NITW,NITW7)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: 2693418 (Party Site)  
(100576-587) TEKPAN - TEKNİK ELEKTRİK KUMANDA PANO  
SAN VE TURİZM TICARET LTD STI  
ANKARA ASFALTI 14 KM  
İSTİKLAL MH 17 SK NO 8 TURKEY

Listee/Classified Co.: 2693418 (Party Site)  
(100576-587) SAME AS APPLICANT

This Follow-Up Service Procedure authorizes the above Manufacturer(s) to use the marking specified by UL LLC, or any authorized licensee of UL LLC, including the UL Contracting Party, only on products when constructed, tested and found to be in compliance with the requirements of this Follow-Up Service Procedure and in accordance with the terms of the applicable service agreement with UL Contracting Party and any applicable Service Terms. The UL Contracting Party for Follow-Up Services is listed on addendum to this Follow-Up Service Procedure ("UL Contracting Party"). UL Contracting Party and UL LLC are referred to jointly herein as "UL."

UL further defines responsibilities, duties and requirements for both Manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in the document titled "UL and Subscriber Responsibilities" that can be located at the following website: <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of these documents from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of these documents or the applicable Service Terms, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified Manufacturer(s) and any Listee/Classified Co. in this Follow-Up Service Procedure must agree to receive Follow-Up Services from UL Contracting Party. If your applicable agreement is a Global Services Agreement ("GSA") with an effective date of January 1, 2012 or later and this Follow-Up Service Procedure is issued on or after that effective date, the Applicant, the specified Manufacturer(s) and any Listee/Classified Co. will be bound to a Service Agreement for Follow-Up Services upon the earliest by any Subscriber of use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees which will incorporate such GSA, this Follow-Up Service Procedure and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/Terms-After-12-31-2011>. In all other events, Follow-Up Services will be governed by and incorporate the terms of your applicable service agreement and this Follow-Up Service Procedure.

## INDEX

MODELS	SECTION	REPORT DATE	Approval
Enclosures for Industrial Control Panels, Sheet metal enclosure Series TEOS and DM.	1	2012-09-20	B

## Approval Abbreviations:

- A - Evaluated to United States Standards only.
- B - Evaluated to United States Standards and Canadian National Standards.
- C - Evaluated to Canadian National Standards only.

## DESCRIPTION

## PRODUCT COVERED:

USL, CNL - Enclosures for Industrial Control Panels, Sheet metal enclosure Series TEOS and DM.

## GENERAL:

Series TEOS and DM metal enclosures, with single and double door, are intended for indoor use, to provide a degree of protection to personnel against incidental contact with the enclosed equipment and to provide a degree protection against falling dirt.

Series TEOS and DM metal enclosures, with single and double door, are intended for indoor use, primarily to provide a degree of protection against dust, falling dirt and dripping non-corrosive liquids.

Series TEOS is suitable for Side-by-Side configuration.

## ENVIRONMENTAL RATING:

Enclosures Series	Door (s)	Type
TEOS	Single	1, 12
	Single with observation window	1, 12
	Double	1
DM	Single	1, 12
	Single with observation window	1, 12
	Double	1